




ELSEVIER

Contents lists available at ScienceDirect

Energy Conversion and Management: X

journal homepage: www.journals.elsevier.com/energy-conversion-and-management-x

Impact of Power-to-Gas on distribution systems with large renewable energy penetration

Andrea Mazza^{a,*}, Fabio Salomone^b, Francesco Arrigo^a, Samir Bensaid^b, Ettore Bompard^a, Gianfranco Chicco^a^a Dipartimento Energia "Galileo Ferraris", Politecnico di Torino, Corso Duca degli Abruzzi 24, 10129 Torino, Italy^b Dipartimento di Scienze Applicate e Tecnologia, Politecnico di Torino, Corso Duca degli Abruzzi 24, 10129 Torino, Italy

ARTICLE INFO

Keywords:

Distribution system
Energy transition
Power-to-Gas
Renewable energy sources
Storage

ABSTRACT

The exploitation of the Power-to-Gas (PtG) technology can properly support the distribution system operation in case of large penetration of Renewable Energy Sources (RES). This paper addresses the impact of the PtG operation on the electrical distribution systems. A novel model of the PtG plant has been created to be representative of the entire process chain, as well as to be compatible with network calculations. The structure of the model with the corresponding parameters has been defined and validated on the basis of measurements gathered on a real plant. The PtG impact on the distribution systems has then been simulated on two network models representing a rural and a semi-urban environment, respectively. The testing has been carried out by defining a set of cases that contain critical situations for the distribution network, caused by RES plant placement. The objectives of the introduction of PtG are the reduction of the reverse power flow, as well as the reduction of the overcurrent and overvoltage issues in the distribution system. The results obtained from annual simulations lead to considerable reduction (from 78 to 100%) of the reverse power flow with respect to the base case, and to alleviating (or even solving) the overcurrent and overvoltage problems of the networks. These results indicate PtG as a possible solution for guaranteeing a smooth transition towards decarbonized energy systems. The capacity factors of the PtG plants largely vary depending on the network topology, the RES penetration, the number of the PtG plants and their sizes. From the test cases, the performance in a rural network (where the minimum capacity factor is about 50%) resulted better than in a semi-urban network (where the capacity factor values range between 21% and 60%).

1. Introduction

In the last years, the increase of Renewable Energy Sources (RES) has changed the paradigm of the distribution system operation, by imposing a shift from the traditional case of a completely passive network to a more and more active network hosting an increasing share of local generation. The local generation is variable during time and can create different issues, such as i) reverse power flow (occurring when the distribution system injects power into the transmission system), and ii) operational constraint violations (in terms of voltage and current limits). For solving these problems without the RES production curtailment, the excess of local generation should be converted and stored in appropriate forms.

The choice of the type of storage to be used depends on the need to use more power (generally with relatively short duration) or more energy (from equipment that guarantee longer autonomy). Power-to-Gas

(PtG) is a solution that can exploit the excess of electricity from the local generation system to produce and store gas, then using the stored gas at a later time for different purposes. These characteristics make PtG adapt to be integrated into multi-energy systems [1,2] and to participate in the energy system operation in a flexible way [3].

In general, PtG plants can be divided into two main product chains:

- *Power-to-Hydrogen*, where the excess of electricity from RES is transformed in hydrogen [4]
- *Power-to-Methane*, where the hydrogen produced is converted in methane through methanation [5]

This paper focuses on the second production chain and aims to study the integration of a PtG plant into a high-RES distribution system.

In the literature, there are relatively few studies that combine both PtG and distribution systems. In [6], the authors have investigated the

* Corresponding author.

E-mail address: andrea.mazza@polito.it (A. Mazza).<https://doi.org/10.1016/j.ecmx.2020.100053>

Received 22 December 2019; Received in revised form 23 June 2020; Accepted 14 July 2020

Available online 18 July 2020

2590-1745/ © 2020 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license

<http://creativecommons.org/licenses/by-nc-nd/4.0/>.

use of an electrolyser as an alternative for network expansion in case of high photovoltaic (PV) penetration. A real network has been modelled and the size of the electrolyser has been obtained by considering the same effect reached by cable substitution. The techno-economic analysis has highlighted that the profitability is greatly depending on the local excess of RES [7]. More in detail, RES electric excess has been used for sizing of the PtG plant capacity, reaching an overall PtG plant efficiency of about 77% (on a LHV basis) and a utilization factor of about 30% [7]. These results have been obtained both optimising the thermal integration between the methanation unit and the electrolyser, and analysing the management of each equipment [7]. The use of a low-voltage (LV) electrolyser has been studied by predicting the temporal variation of excess energy occurring in low voltage networks at 2030 and by identifying appropriate electrolyser capacities, while not considering any network topologies, but only an equivalent energy balance at a single node [8]. In [9], the mitigation effect of electrolysers on the reverse power flow has been exemplified on a LV grid. The evaluation of the use of power-to-methane chain in case of distribution systems characterised by an excess of wind production has been analysed in [10]. The study has been based on the consumption of gas and electricity of a local area, and the use of combined heat and power (CHP) plants locally installed has been considered as well. In [11], the authors have focused on voltage regulation in active power distribution systems, by presenting a new algorithm for the real time scheduling of PtG and Gas-to-Power (GtP) plants by considering also arbitrage opportunities. In [12], the authors have presented a voltage control strategy by coordinating both the On-Load Tap Changer and an alkaline electrolyser modelled dynamically as in [13]. The same electrolyser model has been used in [14] for studying how the electrolyser can be optimally designed and installed for facing the increase of RES in future active distribution networks. The alleviation of reverse power flow, line congestions and power losses in integrated power and gas network has been studied in [15–17], respectively. In those cases, the authors have presented three different scheduling algorithms to properly deploy power-to-methane and GtP conversion unit for distribution network support. The constraints of the chemical plants have been represented in terms of minimum and maximum power and gas flow of the plants.

All the above papers have modelled the PtG units as “black boxes” without considering the physical connections existing among the different plant parts, and thus also auxiliary services (such as compression systems) have been missed by the modelling aspects. Thanks to the multi-disciplinary team composing the project STORE&GO [18], the complete model of a PtG plant¹ has been created and then included in a power flow calculation. For representing the effect on different seasons, the annual irradiation profiles have been considered with reference to the installation sites of the demonstration plants of the project. Furthermore, for understanding the effect on different network topologies, two realistic network models have been introduced to show the effect on both rural and semi-urban grids. Typical load profiles have been included to represent the variability of the loads in time. Great attention has been devoted to the case study creation, by considering different possible positions of the PV plants in the grid.

Regarding the electrical point of view, the PtG plant is a particular type of load, and as such it has to be properly modelled in a power flow calculation tool. PtG plant modelling is an open research issue, especially because of the need of providing a sound validation of the model on the basis of real case applications. On the basis of the previous considerations, this paper presents a number of specific contributions to the modelling and exploitation of PtG in distribution systems, namely:

1. The PtG plant modelling is addressed in order to formulate a steady-state model of PtG to be incorporated in the power flow equation

solvers. The validation of the model is carried out on the basis of measurements collected from a real PtG plant.

2. The impact of PtG on the distribution system operation is then studied through simulations in steady-state conditions. Different loading and RES penetration are considered for reproducing different network issues that may be alleviated by using PtG plants. Dedicated cases are created with different RES penetration, by locating the RES sources at network nodes that correspond to critical conditions for the amount of reverse power flows, as well as for the presence of overcurrent and overvoltage issues in the distribution network.

The rest of the paper is organised as follows. Section 2 presents the characteristics of the PtG plant modelled and highlights the modularity of the proposed model. Section 3 focuses on the creation of the case studies, by considering different PV penetration and location in the two networks. Section 4 shows the results, whereas Section 5 provides the concluding remarks.

2. PtG plant model

The PtG plant consists of a low temperature-based electrolyser (LTE), a buffer and a methanation unit. A simplified scheme of the PtG process is illustrated in Fig. 1. The LTE converts liquid water into gaseous oxygen at the anode and gaseous hydrogen at the cathode through electrolysis [7,19–22]. According to the literature, the efficiency of the electrolysis ranges between 55% and 70% (on a LHV basis) [7,23,24]. The hydrogen produced within the LTE could be stored in a tank or sent to the methanation unit. The hydrogen is mixed in stoichiometric ratio with carbon dioxide (H_2/CO_2 molar ratio equal to 4) in order to supply the methanation unit that produces synthetic natural gas (SNG) [7,19,22].

In addition, the main characteristics of the PtG are summarized in Table 1.

2.1. Characteristics of the electrolyser

A low temperature-based electrolyser is characterised by a power-to-hydrogen efficiency, whereas the methanation unit is characterised by a certain value of the CO_2 conversion efficiency (i.e., 98.5% [7,19,25]).

The PtG model has been built considering the dynamics (start-ups, shutdowns and partial loads) of a real plant installed in the demonstration site of Falkenhagen (Germany), whose process is based on Alkaline Electrolysis (AEC). This plant consists of a 2 MW AEC-electrolyser, which was composed of 6 AEC modules (330 kW each one). The electrolysis technology considered has minimum load $P_{MIN} = 20\%$ [23] and power-to-hydrogen efficiency $\eta_{H_2} = 57.6\%^2$ (real data).

The characteristics of minimum load and efficiency of the AEC technology has been directly provided by the Falkenhagen plant managers, based on their long-time experience in the plant operation. It is worth noting that the AEC efficiency is in line with the related literature [24,26]. Regarding the minimum load of the electrolyser (i.e., the power to be provided for producing the minimum amount of H_2), the values existing in the literature are even lower than 20% but they may lead to problems (see for example [23,27]). The modularity of these technologies simplifies the management of the electrolyser, moreover each module could be maintained in hot stand-by if there is not enough electrical energy for supplying the PtG plant.

On the one hand, the electrolyser has a wide rangeability thanks to its modularity. On the other hand, the methanation reactors have a narrow rangeability due to the kinetics of the methanation reaction [25,28]. More specifically, according to the literature [25], the reactors

¹ From this point, with PtG plant only the power-to-methane chain will be indicated.

² The efficiency refers to the Lower Heating Value.




Fig. 1. Simplified low temperature-based Power-to-Gas process scheme considering H₂ storage.

Table 1
Characteristics of the PtG plant.

Parameter	Value	Parameter	Value
LTE operating temperature	80 °C	CO ₂ conversion within the methanation unit	98.5%
LTE and methanation unit pressure	15 bar	Inlet – outlet temperature of the cooling water	28 – 32 °C
H ₂ tank maximum pressure	60 bar	Coolant temperature in the methanation unit	250 °C
Compression efficiency	75%	Power-to-hydrogen efficiency (LHV basis)	57.6%

are conceived as tube-bundles refrigerated by evaporating water at 250 °C. The methanation reaction is extremely exothermic [28,29]; hence, the tube diameter must be small for avoiding too high radial thermal profiles. Obviously, the design of a methanation reactor is made for the nominal productivity; however, the residence time increases (and the gas hourly space velocity decreases) reducing the productivity. Consequently, the heat generation profile along the axis of the reactor becomes narrower and more intense; in addition, the overall heat exchange coefficient decreases [19,25]. Therefore, it could cause problems of thermal management, hot spots and local deactivation of the Ni/ γ -Al₂O₃ catalyst (i.e. sintering) [7,28–30]. Hence, each reactor could be parallelized in 3 or 4 bundles in order to increase the rangeability of the PtG plant, for instance, from about 60–110% (i.e., only one bundle for each reactor) to about 20–110% (i.e., three bundles in parallel for each reactor). For all these reasons, the best option is to maintain the methanation unit at least at the minimum operative load.

The model developed in this work, as additional feature, considers also all the auxiliary consumptions, which can be easily adjusted according to the actual PtG plant layout. More in detail, the energy consumption of a compressor (E_{compr} , W) was calculated according to Eq. (1) [31], where Z is the compressibility factor that was assumed unitary, R (8.314 J mol⁻¹ K⁻¹) is the ideal gas constant, T_{in} (K) is the inlet temperature, \dot{n}_{in} (mol s⁻¹) is the inlet molar flow rate, γ is the heat

capacity ratio, and η_{compr} is the compression efficiency, which was set equal to 70% and p_{in} and p_{out} represent the inlet and outlet pressure, respectively. In addition, multistage compression was considered if the compression ratio ($p_{\text{out}}/p_{\text{in}}$) was greater than 4.

$$E_{\text{compr}} = Z \cdot R \cdot T_{\text{in}} \cdot \frac{\gamma \cdot \eta_{\text{compr}}}{\gamma - 1} \cdot \left[\left(\frac{p_{\text{out}}}{p_{\text{in}}} \right)^{\frac{\gamma - 1}{\gamma \cdot \eta_{\text{compr}}}} - 1 \right] \cdot \dot{n}_{\text{in}} \quad (1)$$

Moreover, the methanation unit and the electrolyser require an additional electric consumption due to heat dissipations caused by natural convection [7], if they are maintained in hot stand-by.

2.2. The electrolyser model

The dynamic behaviour of the AEC-electrolyser has been obtained from the analysis of a test carried out at the Falkenhagen plant (shown in Fig. 2).

The test had duration of about 11.5 h and highlighted that the AEC-based electrolyser had a fast response when the setpoint changed. Therefore, its response could be modelled for the purpose of forecasting the behaviour of the AEC-based electrolyser when it is coupled with an intermittent RES-based electrical profile. It is worth mentioning that during the test, the set point of the electrolyser was periodically




Fig. 2. Falkenhagen test on an AEC-based electrolyser.

changed with steps of different amplitude to explore a large number of operating conditions.

The easiest model to describe the AEC-based electrolyser behaviour is a first order system with delay, which is characterised by three parameters; the mathematical model of its response to a step is described by means of Eq. (2) [32–34]:

$$\begin{cases} y(t) = 0 & \text{If } t < \alpha \\ y(t) = A \cdot K \cdot \left[1 - \exp\left(-\frac{t-\alpha}{\tau}\right) \right] & \text{If } t \geq \alpha \end{cases} \quad (2)$$

In this equation, $y(t)$ is the actual power of the AEC-based electrolyser (MW) at the time step t (s), A is the step amplitude of the setpoint (MW), K is the gain of the system, α is the time delay of the response (s), τ is the time constant of the system (s). The gain K can be evaluated by means of Eq. (3), where $y(\infty)$ is the actual power of the electrolyser after a large period of time (stationary condition):

$$K = \frac{y(\infty)}{A} \quad (3)$$

The two time parameters (α and τ) have been estimated by means of the Sundaresan and Krishnaswamy’s method [35], according to Eqs. (4) and (5), respectively. The two parameters were calculated using two characteristic points of the response curve: t_1 represents the time in which the response reaches 35.3% of the stationary value $y(\infty)$, while t_2 is estimated as the time in which the response reaches 85.3% of the final value $y(\infty)$:

$$\alpha = 1.3 \cdot t_1 - 0.29 \cdot t_2 \quad (4)$$

$$\tau = 0.67 \cdot (t_2 - t_1) \quad (5)$$

For the purpose of evaluating these three parameters, four steps with the same amplitude (i.e., 0.3 MW) have been considered, by obtaining the parameters shown in Table 2. These steps are highlighted in Fig. 2 between 40 min and 100 min of the test.

The fit between the model output and the real data is shown in Fig. 3.

2.3. Simulation algorithm of the PtG plant model

The flowchart of the simulation algorithm (called in the sequel

Table 2
Characteristics of the low temperature-based electrolyser.

Parameter	Value
K	1
α [s]	14.62
τ [s]	11.73




Fig. 3. AEC-based electrolyser response model estimated using Falkenhagen test data (first order system with delay). It is worth noting that the experimental data (red spots) refer to the four steps considered for the modeling, as mentioned in the text. For comparing the behavior of the response, the starting values of the real steps were shifted to zero (baseline), and thus some data are overlapping.

function PtG) is shown in Fig. 4.

The simulation algorithm consists of the following main instructions:

- **Setpoint:** the setpoint is defined as the theoretical maximum operative power at which the electrolyser may work. This maximum can correspond to either the power provided by the grid (when it is lower than the nominal power of the electrolyser) or the nominal power of the electrolyser (in the case it exceeds the nominal power of the electrolyser).
- **Actual power:** it represents the actual electric consumption that could be calculated using the dynamic model of the AEC-based electrolyser (Section 2.2).
- **Hydrogen production:** the hydrogen flow could be evaluated taking into account the efficiency of the electrolyser.
- **Hydrogen tank management:** if the electrolyser is operative, a minimum hydrogen flow feeds the methanation unit. Beyond this, certain amount of hydrogen is sent to a hydrogen tank until the tank is completely full (the priority is filling the tank). This operation allows to decouple the methanation unit from the electrolyser. When the electrolyser is not operative, the stored hydrogen is fed to the methanation unit, for producing continuously SNG. In this case, the methanation unit works at the minimum power load; when the hydrogen tank is completely empty, it could be turned off and




Fig. 4. Flowchart of the algorithm (function_PtG).

remain in hot standby conditions³. More in detail, H₂ produced in the LTE could be split into two streams. During the filling of the H₂ tank three configurations have to be considered:

- ◆ If the H₂ tank is empty, its pressure is lower than the operative pressure of both the LTE and the methanation unit. Therefore, the compressor (P-102) is useless and the H₂ tank could be partially filled using stream 9 until the storage pressure is equal to the operative pressure of the LTE.
- ◆ If the H₂ tank is partially filled, its pressure ranges between the operative pressure of the LTE and the maximum storage pressure. Therefore, the compressor (P-102) is used for filling the tank until it is completely full.
- ◆ If the H₂ tank is completely full, the produced H₂ is directly fed to the methanation unit using stream 16.
- If the LTE does not produce H₂, the methanation unit could be fed using the stored H₂. In this case, three configurations could be possible:
 - ◆ If the tank pressure is higher than the operative pressure of the methanation unit, H₂ could be fed to the methanation unit through stream 14.
 - ◆ If the tank is emptying, H₂ could be fed to the methanation unit using the compressor P-103 until the tank is completely empty.
 - ◆ If the H₂ tank is empty and no electricity is available for producing H₂, the methanation unit must be turned off (shutdown of the PtG plant).

- *Auxiliary consumptions*: all the consumptions of the auxiliary items of equipment are related to the amount of produced hydrogen. Firstly, the hydrogen could be compressed; secondly, the carbon dioxide has to be compressed; thirdly, the water has to be pumped and lastly it must be heated up to the temperature of the electrolyser.
- *Control of the setpoint*: the setpoint power of the electrolyser must be recalculated considering the new auxiliary consumptions, because the available electricity is comparable with the power absorbed by the electrolyser. This affects the power withdrawn from the power grid.
- *Methanation unit*: the amount of SNG could be calculated using the CO₂ conversion, or alternatively, the hydrogen-to-SNG efficiency.

3. Creation of the case studies

As widely shown in literature (for example in [36]), the installation of large share of RES can create the following issues in the electrical networks:

- *Reverse power flow (RPF)*: on the one hand, a reverse power flow affects the transmission system because the point of connection between transmission and distribution system becomes equivalent to a non-controllable active node. On the other hand, the presence of reverse power flow can create issues also at the distribution system, for example in terms of not proper protection schemes. Usually, these problems are nowadays solved by cutting the excess of production or using some pilot battery-based storage [37].
- *Overcurrent (OC)*: the large share of RES can create overcurrents along the feeders. These overcurrents can affect only a portion of the network (e.g., the last portion) or the entire network, depending on

³ A hot standby condition (it means that the equipment is maintained at the operative temperature conditions with auxiliary energy, in order to ensure a fast start up) was assumed for the main equipment (electrolyser and methanation unit).




Fig. 5. PV profiles considered for building the case studies. Four months have been considered (January, April, July and October): (a) semi-urban network and (b) rural network.

the level of load and distributed generation, together with the geographical position of the PV plants.

- **Overvoltages (OV):** this problem is characteristic especially of rural networks, composed of long feeders (also up to 10 km), and characterized by a high R/X ratio, which leads to have to voltage level changes strictly linked with the active power flowing in the grid branches.

It is worth noting that the presence of reverse power flow leads to the network operating in an alert condition, whereas the presence of overcurrent and overvoltage are symptoms of an emergency condition (because directly affecting the operational constraints of the network) [38]. Hence, the distribution system operators needs to solve these problems as soon as possible, by making use of different approaches which can even result in lower quality of service (e.g., load disconnections). So, the simulations carried out starting from conditions in which the network constraints are not satisfied (even though these conditions do not correspond to real situations) have the goal to show, in very extreme cases, how the potential use of PtG can alleviate these problems as well.

The creation of the case studies needs the proper placement of the PV plants. In this study, the placement of the PV plants has been carried out by using two different approaches:

- **Topological approach:** the PV plants have been installed according to the length of the network lines.
- **Losses Allocation Factors-based approach:** in this case, the approach shown in [39] and based on [40] has been adopted. A detailed analysis on the implication of the use of the loss allocation for distribution system analysis can be found in [41].

These approaches are followed by using a series of assumptions on the model of the distribution system, namely, (i) the power flow is calculated as an equivalent single-phase circuit. This is justified in medium voltage networks (to which PtG is connected, because of its size), where loads and generations are usually distributed in a relatively uniform way on the three phases; (ii) the distribution system is analysed in time as a succession of steady state conditions, in which constant

average power withdrawn/injected by loads and local generations in every time step are considered for the power flow calculations. This also implies that the frequency is considered constant (at 50 Hz) during the entire simulation horizon. The use of more detailed dynamic models for the electrical system, which would be able to represent real-time phenomena at milliseconds to seconds scale, is not needed for the type of analysis carried out in this paper; and (iii) the network parameters are known and constant during the entire simulation horizon, which is a usual assumption made in the power flow calculations. This implies that external conditions (such as temperature, etc.) do not affect the parameters (e.g., loads or branch resistances).

3.1. The network samples

This work considers two network samples:

- **Semi-urban network,** adapted from the one shown in [42], by adding time-varying loads with different profiles. For this network only the topological PV placement has been applied [43].
- **Rural network,** developed in the project *Atlantide* [44]. For this network, both PV placement methods have been used.

The two network samples aim to represent different network topologies and allow to emulate the distribution systems in the areas where the demo sites of the project are installed. The two demo sites are installed in Solothurn (Switzerland) and in Troia (Italy). In particular, the semi-urban network refers to Solothurn area, whereas the rural network refers to Troia area.

Few samples referring to daily PV profiles in different months for the two networks are shown in Fig. 5, whereas the load profiles are shown in Fig. 6. It is worth noting that the PV profiles are different for the two network samples because referring to two different geographic locations, and have been obtained from [45].

Moreover, during the night time the PtG plant is supplied by the main grid to guarantee the continuous operation of the plant in compliance with its minimum power specified in Section 2.1 (i.e., $P_{\text{MIN}} = 20\%$).




Fig. 6. Load profiles used in (a) semi-urban network and (b) rural network [44].




Fig. 7. The main calculation loop of the distribution system. The function called function_PtG represents the PtG complete model.

3.2. Introduction of the PtG plant model into the calculation loop of the network operation

The model of the PtG explained in Section 2 needs to be integrated in the network solver, which is based on the Backward Forward Sweep (BFS) method [46]. The response of the PtG unit is modelled as a first order system and solved through the Matlab®-embedded solver ode45. The calculation loop is shown in Fig. 7. The variables used in the calculation loop are presented in Table 3.

After having loaded the inputs, the algorithm runs the BFS for the

Table 3

Input parameters of the main calculation loop.

Inputs	Description
N_{time_steps}	Number of time steps of the analysis
PtG data	Number of the PtG plants N_{PtG_plants} , their positions (indicated by the nodes contained in the set \mathcal{N}_{PtG}) and their sizes
$H_{2, tank}^{(0)}$	Initial value of the matrix of dimensions $\{N_{PtG_plants}, N_{time_steps}\}$ representing the volume of H_2 in the tank in time
N_{keep_steps}	Number of points for running PtG model
Network data	Set of the network nodes \mathcal{J} , set of the network branches \mathcal{B} , number of nodes N_{nodes} , number of branches $N_{branches}$, line parameters, incidence matrix, rate nodal power, lines thermal limits
Load and generation profiles	Load and generation profiles for evaluating the initial value of the matrix $S_{net}^{(0)}$, i.e., the net nodal power (dimensions $\{N_{nodes}, N_{time_steps}\}$)
RPF	Matrix of dimensions $\{N_{branches}, N_{time_steps}\}$ containing the value of reverse power flow at every time step
OC	Matrix of dimensions $\{N_{branches}, N_{time_steps}\}$ containing the value of overcurrent for every branch during the time span of simulation
OV	Matrix of dimensions $\{N_{branches}, N_{time_steps}\}$ containing the value of overvoltages for every node during the time span of simulation
P_{PtG_set}	Matrix of dimensions $\{N_{PtG_plants}, N_{time_steps}\}$ containing the set points of the PtG plants
P_{PtG}	Matrix of dimensions $\{N_{PtG_plants}, N_{time_steps}\}$ containing the actual power that the PtG plants are able to accept (linked to their sizes)

first time: this is requested for defining the network conditions (i.e., nodal voltages and branch currents). On the basis of this, the h -th column of the matrix RPF (containing the value of RPF at every branch the interaction h) is updated. At the same time, the h -th columns of both matrices OV and OC are updated with the values of overvoltage and overcurrent, respectively. On the basis of the above values, a *compound set point* $P_{PtG_set}[h]$ is produced, and is referred to the RPF and overcurrent value of the branch upstream with respect to the node of the PtG plant, while the contribution regarding the overvoltage is linked to the overvoltage value of the node where the PtG plant has been installed as presented in Eq. (6), i.e.:

$$P_{PtG_set}[h] = f(RPF[h], OV[h], OC[h]) \quad (6)$$

In particular, the different set point components are set as follows:

- *Component referring to the RPF*: this component is equal to value of power needed for eliminating the reverse power flow in the upstream branch with respect to the node where the PtG plant is installed.
- *Component referring to the OC*: this component is equal to the value of power that, absorbed from the PtG plant, would help to reduce (at 80% of the thermal limit) the current flowing in the upstream branch with respect to the node where the PtG plant is installed.
- *Component referring to the OV*: this component is equal to the value of power that, absorbed from the PtG plant, would help to reduce (at 1.05 pu) the voltage of the node where the PtG plant is installed.

3.3. Installation and sizing of the PtG plants

The study of the impact of the PtG plants on the distribution system requires to i) choose the node where the plants are installed and ii) their sizes. These two elements are requested by the calculation loop shown in Fig. 7, and in this work have been solved by applying the Simulated Annealing (SA) method [47]. It is worth noting that the main goal of this paper is not introducing a new algorithm for the siting and sizing of the PtG plants, but creating meaningful case studies to get insights regarding the *impact of the PtG plants* on distribution system operation. However, the step regarding the siting and sizing is requested as preliminary task, for emulating the process that, in the future, could bring to rationally install a defined number of MW-scale PtG plants. Few notes regarding the use of the SA in this work are reported in Appendix.

The objective functions used in the algorithm have as main variables the value of reverse power flow, overcurrent and overvoltage of the network. In particular, the network with the installed PtG plants (denoted as X) can be affected by:

- Only reverse power flow
- Reverse power flow and overcurrent
- Reverse power flow and overvoltage
- The combination of the last two cases

All the cases make use of a penalised objective function where the constraints of the problem are integrated within the objective function through penalisation factors indicated with the Greek letter ρ . This approach allows driving the optimisation towards solution with no constraint violations. In particular, the operational constraints are the voltages V_j of the network nodes and the currents I_b flowing in the network branches, which have to remain inside the following ranges:

- $V_j^{(min)} \leq V_j \leq V_j^{(max)}$, with $j \in \mathbf{J}$, where \mathbf{J} denotes the set of nodes. The node voltage is usually expressed in per unit (pu) with respect to the nominal voltage (i.e., $V_j = 1$ means that the voltage value of the node j is equal to the nominal voltage of the system). Usual values of the extremes of the range are $V_j^{(min)} = 0.9$ pu and $V_j^{(max)} = 1.1$ pu.
- $I_b \leq I_b^{(th,max)}$, with $b \in \mathbf{B}$, where \mathbf{B} denotes the set of branches. The value of $I_b^{(th,max)}$ is strictly depending on the conductors installed.

The objective function at the iteration k of the method in case of existence of the sole reverse power flow is shown in Eq. (7):

$$f_k(\mathbf{X}) = \frac{RPF_k}{RPF_0} \cdot \left(1 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(max)} - V_j^{(worst)}}{V_j^{(max)}} \right)^2 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(min)} - V_j^{(worst)}}{V_j^{(min)}} \right)^2 + \sum_{b \in \mathbf{B}} \rho_I \left(\frac{I_b^{(th,max)} - I_b^{(worst)}}{I_b^{(max)}} \right)^2 \right) \quad (7)$$

The penalised objective function at the iteration k is expressed in pu with respect to the value of the reverse power flow in the initial configuration. The reverse power flow is evaluated here through the number of minutes in which it is present during the entire period of analysis. The formulation penalises (through the factors ρ_V and ρ_I) all the configurations that do not respect the operational constraints (i.e., maximum and minimum voltage, and thermal limits) of the network. Thus, the constraints of the objective function (7) are the operational constraints of the network $V_j^{(max)}$, $V_j^{(min)}$ and $I_b^{(th,max)}$, for node j and branch b , respectively. For every node/branch the *worst* condition (e.g., the maximum current $I_b^{(worst)}$ during the day) is chosen as representative value to force the worst condition respecting the imposed constraint.

When both overcurrent and reverse power flow exist in the initial configuration, the objective function is modified as reported in Eq. (8):

$$f_k(\mathbf{X}) = \left(\frac{RPF_k}{RPF_0} + \frac{OC_k}{OC_0} \right) \cdot \left(1 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(max)} - V_j^{(worst)}}{V_j^{(max)}} \right)^2 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(min)} - V_j^{(worst)}}{V_j^{(min)}} \right)^2 \right) \quad (8)$$

In this case, the objective function is still expressed in pu with respect to the initial configuration. The normalised sum of the minute of overcurrent and the minute of reverse power flow during the entire time horizon are modified according to the product of the penalty factors and the value of the constraint violation. In this case, the constraints are the maximum and the minimum voltage values, indicated as $V_j^{(max)}$ and $V_j^{(min)}$, respectively.

The objective function in case both overvoltage and reverse power flow exist is shown in Eq. (9) and differs with respect to Eq. (8) only for the constraints considered, i.e., related to the branch thermal limits $I_b^{(th,max)}$ and the minimum nodal voltages $V_j^{(min)}$:

$$f_k(\mathbf{X}) = \left(\frac{RPF_k}{RPF_0} + \frac{OV_k}{OV_0} \right) \cdot \left(1 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(min)} - V_j^{(worst)}}{V_j^{(min)}} \right)^2 + \sum_{b \in \mathbf{B}} \rho_I \left(\frac{I_b^{(th,max)} - I_b^{(worst)}}{I_b^{(max)}} \right)^2 \right) \quad (9)$$

When all the issues listed above (i.e., reverse power flow, overvoltages and overcurrents) affect the grid, then the objective function is changed to solve them, as shown in Eq. (10):

$$f_k(\mathbf{X}) = \left(\frac{RPF_k}{RPF_0} + \frac{OV_k}{OV_0} + \frac{OC_k}{OC_0} \right) \cdot \left(1 + \sum_{j \in \mathbf{J}} \rho_V \left(\frac{V_j^{(min)} - V_j^{(worst)}}{V_j^{(min)}} \right)^2 \right) \quad (10)$$

It is worth noting that in Eq. (10) the constraint related to the minimum voltage value is still considered as part of the penalized objective function, to avoid that the worst value reached by the voltages in the period under analysis $V_j^{(worst)}$ falls below the minimum allowed value $V_j^{(min)}$.

As the final comment, the above objective functions are chosen *a priori* according to the network issues that affect the distribution system under analysis.

4. Results and discussion

4.1. Annual simulation

4.1.1. Network performance indexes

Different PV penetrations have been assumed for the creation of the case studies. The penetration has been calculated in terms of *share of the*

energy provided by the PV plants with respect to the system passive load considering the PV production in July. In the case with 40% of PV penetration, the production in July covers 40% of the passive load. According to this, the PV penetration in other months varies following the different PV profiles.

The considered case studies and the existing problems in the different cases are shown in Tables 4 and 5 for the semi-urban network and the rural network, respectively. The tables show entries different from zeros when that kind of problem exists, and the entry indicates the magnitude of the problem. The label “Pre” in the table indicates the magnitude of the problem without PtG installed, whereas the label “Post” refers to the condition when PtG plants have been installed. The RPF has been indicated in MWh, whereas the OC and OV are expressed in minutes.

The values refer to annual simulations. The two tables show the number of plants installed and, only for the rural network, the size of the plants as well. Due to the large number of plants installed in the case of semi-urban network, the sizes of the plants are summarised in Fig. 8.

First of all, it is evident that, while in the rural network is possible to obtain cases with problems of overvoltages and reverse power flow, in the semi-urban network is difficult to decouple overvoltage and overcurrent. This is linked with the nature of the lines composing the network, which are highly resistive for the rural network because mostly composed of long overhead lines.

It is worth noting that, as demonstrated through the rural network, the reverse power flow issue is not strictly linked to overvoltage problems, but these two aspects can be decoupled through a suitable

Table 4
Case studies for the semi-urban network.

Case number	Length [km]*	PV penetration	RPF [MWh]		OC [min]		OV [min]		Number of PtG plants
			Pre	Post	Pre	Post	Pre	post	
1	$0 < L \leq 0.45$	40%	11,298	9.37	–	–	–	–	7
2		80%	151,920	33,654	90,616	35	–	–	20
3	$0.5 \leq L \leq 3$	40%	10,213	31.4	430,087	6,978	3,356	0	12
4		60%	71,272	7,165	2,388,634	25,156	900,407	0	17

* The length refers to the branches of the MV semi-urban network.

Table 5
Case studies for the rural network.

Case	Method PV placement	Length* [km]	PV penetration	RPF [MWh]		OC [min]		OV [min]		Number of PtG plants	Size [MW]
				pre	post	pre	post	pre	post		
5	Topological	$0 < L \leq 0.9$	40%	266.27	0	–	–	–	–	1	2.5
6			80%	19,861	1633.9	165,047	0	504	–	4	2 (all)
7		$2 \leq L \leq 3$	40%	248.99	0.10	–	–	–	–	1	2
8			80%	19,206	3,337.4	–	–	276,329	0	4	2 (three plants) 1.5 (one plant)
9	Loss allocation	–	40%	167.90	0	–	–	–	–	2	2 (all)
10			80%	20,991	1868.4	–	–	–	–	4	2 (all)

* The length refers to the branches of the MV network.




Fig. 8. Number and sizes of the PtG plants installed in the semi-urban network.

installation of PV generation (as the one guaranteed by the procedure shown in [39]).

From the two tables it is evident that the deployment of PtG has a positive impact on alleviating the grid issues.

For the *semi-urban network*, in the cases in which the PV is installed at the end of lines with length L lying in the range $0 < L \leq 0.45$ km, the impact of PtG is indeed powerful, because both cases reveal how the reverse power flow can be strongly reduced: in fact, in case of PV penetration equal to 40% the reduction is over 99.9% (passing from almost 11.3 GWh to 9.37 MWh), whereas with PV penetration equal to 80% the reduction is almost 78% (passing from almost 152 GWh to 34 GWh). In the cases with PV plants installed at the end of lines with length L lying in the range $0.5 \leq L \leq 3$ km, the reduction of reverse power flow is stronger for lower PV penetration (more than 99.6% with PV penetration equal to 40%), but is anyway high also with PV penetration equal to 60% (the reverse power flow reduction reached almost 90%). Residual problems of overcurrents appear in all the cases except Case 1.

By analysing the worst case (i.e., the one with PV penetration equal to 60%), these issues affect in total thirteen branches, and the number of minutes in which the lines are overloaded lies between 4 and 5,456 min, whereas the maximum overload conditions at which they

Table 6

Analysis of the overloaded lines in of semi-urban network, with 60% of PV penetration.

Lines overloaded	Cumulative overload period [min]	Maximum overloading [%]
6	284	11.47
32	13	9.02
152	79	13.39
155	5,032	9.05
156	4,747	8.86
157	5,456	10.10
159	2,717	6.12
161	910	17.33
165	1,395	2.43
169	4,382	7.62
170	123	13.10
185	4	2.24
196	14	4.78

operate lies in the range between 2.24% and 13.39%, as shown in Table 6. The system operator has to act for establishing again the proper network conditions, because the alleviation effect of the PtG deployment cannot solve completely the overcurrent issues.

For the rural network, in the cases in which the PV is installed at the end of lines with length L lying in the range $0 < L \leq 0.9$ km, the impact of PtG is again powerful, because in one case (i.e., PV penetration equal to 40%) the reverse power flow is completely solved, whereas in the case with 80% of PV penetration the reverse power flow is strongly reduced, passing from 19,861 GWh to 1,633.9 MWh (reduction of almost 92%). In the cases with PV plants installed at the end of lines with length L lying in the range $2 \leq L \leq 3$, the reduction of reverse power flow is stronger in case of lower PV penetration (almost 100% with PV penetration equal to 40%), but is anyway high also with PV penetration equal to 80% (the reverse power flow reduction reached almost 83%).

Finally, the case created with the rural network by using the loss allocation shows that the reverse power flow problem can be solved in




Fig. 9. Capacity factors for the different cases of semi-urban network.

Table 7
Annual capacity factors for the rural network.

Case	PV penetration	Min capacity load [%]	Max capacity load [%]
5	40%	47.55*	–
6	80%	43.47	54.96
7	40%	47.10 ⁴	–
8	80%	48.50	56.0
9	40%	43.07	49.26
10	80%	45.68	50.88

* These cases require only one PtG plant.

Table 8
Network losses for both the semi-urban network and the rural network.

Case	Power Losses [MWh]		Power Losses [%]		Case	Power Losses [MWh]		Power Losses [%]	
	pre	post	Pre	post		pre	post	pre	post
1	2,122.5	2,314.9	0.95	0.20	5	1,149.8	1,128.9	2.22	1.82
2	3,445.1	2,902.4	7.36	0.69	6	2,040.0	1,363.1	9.34	2.38
3	3,779.0	3,278.7	1.71	0.28	7	1,142.5	1,042.1	2.21	1.74
4	6,517.5	4,082.1	4.86	0.50	8	2,683.5	1,972.0	12.29	3.82
					9	1,263.9	1,205.9	2.42	1.77
					10	20,991	1,358.0	7.68	2.51

case of 40% of PV penetration, whereas a residual reverse power flow remains for the case 80% (but even in this case the reduction is more than 90%).

4.1.2. Capacity factors

The successful use of PtG plants needs a justification in terms of plant use, i.e., a *capacity factor* high enough.

The capacity factor $C_f^{(i)}$ that refers to the i -th PtG unit is the ratio between the energy $E_{PtG}^{(i)}$ consumed by the i -th PtG unit during the simulation period Δt and the theoretical energy that the plant would be able to absorb during the same time period if it had consumed its nominal power; it was calculated according to Eq. (11):

$$C_f^{(i)} = \frac{E_{PtG}^{(i)}}{P_{n,PtG}^{(i)} \cdot \Delta t} \quad (11)$$

where $E_{PtG}^{(i)}$ is the energy consumed during the simulated time horizon Δt by the i -th PtG plant, and $P_{n,PtG}^{(i)}$ is the nominal power of the i -th PtG plant.

Fig. 9 shows the capacity factors for the semi-urban network. It shows that in Case 1 the plants result underused, and thus the number of plants chosen is too high. A reduction of the number of plants installed could lead to a more fruitful use of the plants. In Case 2, only one plant results underused (i.e., having capacity factor equal to 23%), whereas the other plants are quite well exploited.

Case 3 presents 12 plants having a capacity factor lying in the range 40%–50%, whereas the remaining plants have a capacity factor between 50% and 60%.

Finally, Case 4 presents three plants with capacity factor lower than 40% (i.e., from 28% to 37%), whereas all the other plants are well exploited (minimum about 51%).

From the results it is evident that the number of plants installed has a great impact and need to be carefully considered. The analysis carried out, in any case, neglects the presence of suitable gas network points: in the reality, the presence of real infrastructures will limit the potential nodes where PtG can be installed to a smaller number than the one considered here.

In the case of the rural network, the results are summarized in Table 7. With respect the previous case, the minimum capacity factor results higher than 60% in all the cases, and reaches almost 90% in one case. The results in the table indicate also for this case that PtG can handle very well the issues created from PV generation installed at the end of relatively long lines, by maintaining a sufficiently high capacity factor.

A good performance index of the network is the value of the power losses, which are summarized in Table 8.

The value of the losses (in MWh and in percentage) is reduced in all the cases. This reduction is obtained thanks to the installation of the plants that help to improve the network operation.

Another performance indicator is the voltage magnitude (maximum and minimum), whose values for both semi-urban and rural networks

are shown in Table 9. It is evident the effect of PtG to reduce the voltage at levels that are lying within the admissible ranges.

4.2. Network effect

This section aims to highlight the role of the network infrastructure in the proper evaluation of the effect of the PtG deployment.

In fact, some approaches existing in literature (e.g., [7]) do not consider the existence of the electrical infrastructure, but only the potential unbalance between local generation and loads. However, this approach could not be proper for solving completely the issue caused by the excess of RES.

Taking as example a particular day of Case 5⁴, the difference between generation and loads, without taking into account the network, is shown in Fig. 10. The same figure also reports the actual reverse power flow existing in the network. The two curves are quite similar, but the first one overestimates the actual reverse power flow value.

For the sake of clarity, the rural network schematic is shown in Fig. 11.

The installation of plants characterised by different size at node 2 (connected to the network slack node) instead of node 83 (as in Case 5) leads to the results shown in Table 10. The solutions show that the

⁴ The day considered has as PV profile the one shown in Fig. 5b, Month July.

Table 9
Minimum and Maximum voltage magnitude for both semi-urban and rural networks.

Case	Minimum voltage [pu]		Maximum voltage [pu]		Case	Minimum voltage [pu]		Maximum voltage [pu]	
	pre	post	pre	post		Pre	post	pre	post
1	1.00	1.00	1.04	1.03	5	0.93	0.93	1.05	1.04
2	1.00	1.00	1.06	1.05	6	0.93	0.93	1.11	1.06
3	1.00	1.00	1.11	1.09	7	0.93	0.93	1.07	1.03
4	1.00	0.93	1.15	1.04	8	0.93	0.93	1.14	1.09
					9	0.93	0.92	1.05	1.01
					10	0.93	0.93	1.06	1.05




Fig. 10. Comparison between the actual reverse power flow (with and without the network).

reverse power flow issue can be almost completely solved by using a plant with smaller size than the one referring to Case 5. This may lead to think that the solution of Case 5 could be not optimal, because of the size. However, the capacity factor highlights that the installation of the plant at the node connected to the slack bus does not guarantee a good utilisation of the potential of the plant and thus the installation node should be carefully chosen. Furthermore, the use of the plant with

the position and size of Case 5 allows improving the network conditions, in terms of power losses and reverse power flow. This simple example aims to be an effective way to show the importance of the network information to capture all the aspects regarding the new operation of the electrical system when new devices are installed.

4.3. Response of the PtG model

The PtG model provides in output the following quantities:

- Power profile sent by the control system to the electrolyser $P_{elec,sp}$
- Power profile of the electrolyser P_{elec}
- Power profile of the auxiliary services P_{aux} , referring to i) the CO₂ compression system, ii) the circulation of H₂O, iii) the compression of the H₂, and iv) the water heating.
- The hydrogen flow rate sent to the tank $\varphi_{H2,tank}$ [kmol/s]
- The hydrogen sent to the methanation unit directly from the electrolyser $\varphi_{H2, dir}$ [kmol/s]
- The hydrogen sent to the methanation unit from the tank after compression $\varphi_{H2,tank,meth}$ [kmol/s]
- The level of the hydrogen tank [%]
- The SNG produced seen as power profile [MW] or energy profile [MWh]

With reference to the same day considered in Section 4.2 of Case 5, $P_{elec,sp}$, P_{elec} and P_{aux} , are shown in Fig. 12. In Fig. 12(a), it is evident the saturation imposed by the nominal power of the plant. Furthermore, the minimum power required by the AEC is different from zero and has to be provided by the main network. Fig. 12(b), instead, shows the power related to the auxiliary services. Three zones with different auxiliary service power exist, and each of them is characterized by different contributions, as highlighted in Fig. 13. More specifically, during the night no excess of electrical power is available for the PtG plant; therefore, it operates at the minimum power load corresponding to 20% of the nominal installed power. As illustrated in Fig. 13(a) auxiliary consumptions are principally due to the CO₂ compression, while water pumping and H₂ compression are marginal contributions. Subsequently, in the first




Fig. 11. Rural network.

Table 10
Comparison between the network performance without PtG, with PtG installed without optimisation process and with optimisation process (referring to a day of Case 5).

Size [MW]	Reverse power flow [MWh]	Reverse power flow [min]	Power Losses [MWh]	Power Losses [%]	Capacity factor [%]
0 (no PtG)	2.16	151	3.08	2.29	–
0.5	1.026	143	3.09	2.24	50.81
1	0.284	139	3.096	2.20	44.21
1.5	0.062	135	3.102	2.17	36.02
2	0.025	120	3.108	2.14	30.44
2.5	0.022	110	3.114	2.11	27.03
2.5 (day of Case 5)	0	0	3.00	1.85	69.22

part of the day (between 6 h and 11 h) the electrical availability increases, and the electrolyser could work in its whole operative range (from 20% to 100%); thus, it produces a large amount of H₂, which is mainly stored in the tank until it is completely full. Hence, H₂ compression represents 96% of all auxiliary consumptions, as shown in Fig. 13(b). At the same time, the methanation unit operates at the

minimum power load for allowing the tank to be filled: in fact, the CO₂ compression represents 3% of the auxiliary consumptions even though it is the minimum power consumption for compressing CO₂. Lastly, in the second part of the day (between 11 h and 18 h), both the electrolyser and the methanation unit work in their whole operational range and the H₂ tank is entirely full. More in detail, as depicted in Fig. 13(c), H₂ has not to be compressed and the CO₂ compression cost increases as the CO₂ flow rises (H₂ and CO₂ are fed in stoichiometric ratio to the methanation unit). Furthermore, all these aspects of the process are clearly illustrated in Fig. 14. As shown in Fig. 14 (a and b), the H₂ tank is filled during the first hours of the day, when there is a large excess of electrical energy availability. Subsequently, both the electrolyser and the methanation unit operate for producing SNG, as depicted in Fig. 14 (b and c). In this case study (one day of Case 5), the alkaline electrolyser absorbs 28 MWh of electricity, which is converted into 237.4 kmol of H₂ (15.8 MWh, LHV basis). Initially, the produced H₂ is partially stored in the tank (50.9 kmol) until it is completely full; subsequently, the H₂ flow is sent to the methanation unit for producing SNG (10.4 MWh, LHV basis). In this case study, the auxiliaries require 0.21 MWh of electrical energy during the whole day. It is worth noting that the tank is not discharged, because the minimum operative power set for the electrolyser was assumed to be




Fig. 12. Electrical quantities provided by the PtG model: (a) input power profiles and (b) power profile of the auxiliary services.




Fig. 13. Composition of the auxiliary services in the different periods of the day.




Fig. 14. (a) H₂ tank filling, (b) H₂ molar flow rates and (c) SNG productivity of the PtG plant.

20% (as specified in Section 2), which is equal to the minimum flow required by the methanation unit. However, the model includes also the storage system, which can intervene if a different control is applied.

5. Conclusions

This paper has presented a detailed study regarding the impact of PtG technology on the electrical distribution system. The study takes into account both electrical aspects and information related to the process chain leading to the SNG production.

Thanks to the physical model of the PtG plant, the evaluation of the values of its internal variables (e.g., hydrogen flows) can be checked, and this allows acting on the downstream portion of the plant, i.e., methanation plant and hydrogen buffer.

Furthermore, the request of energy to supply the auxiliary services can be successfully evaluated. It is worth noting that the plant layout can be changed, both in terms of control and in terms of components adopted.

From the electrical point of view, this paper shows that the evaluation of the impact of PtG plants on the distribution system has to consider the *local* network conditions, because different network samples lead to different problem to be solved. The knowledge of the type of network where the plants will be installed is thus fundamental, and has been presented here by considering two network samples.

Furthermore, the level of RES penetration is another important aspect to be taken into account, due to the different network issues introduced. From the paper results it was evident the difference between alert and emergency network operation, which linked to different variables (reverse power flow and network constraints, respectively).

For the semi-urban network, the number and the sizes of the PtG plants are higher than the ones used for the rural network, due to the higher number of nodes and higher load. The results obtained are significantly good, with a reduction of the reverse power flow energy falling in the range 78–100%, with better performances for lower PV penetration. Furthermore, in all the cases the installation of PtG plants has reduced the network losses of the network and no undervoltage problems have been found during the year, even with scarce solar radiation (i.e., in winter months).

By considering the rural network, the case $0 < L \leq 0.9$ km sees a reduction of the reverse power flow energy falling in the range 92–100%, whereas in the case $2 \leq L \leq 3$ km the reduction lies in the range 83–100%. In all cases, the installation of PtG is also able to alleviate the problems due to violations of constraints if PtG is absent, by reaching the complete elimination of these violations for the lower PV penetrations.

The load factor of the plants provides information on how much a PtG plant is used: these values strongly depend on the network conditions (correlated to the PV penetration value), as well as on the positioning of the

Appendix

The Simulated Annealing (SA) algorithm is composed of an external loop (shown in Fig. 15a) and an internal loop (shown in Fig. 15b).

The external cycle depends on a control parameter called C , whose initial value is named C_0 . For every iteration m greater than 0 of the external cycle, the control parameter is updated with a certain velocity described by the cooling rate, i.e.:

$$C_m = \alpha \cdot C_{m-1} \quad (12)$$

The stop criterion of the external cycle is based on the persistence of the solution found so far: once the solution found persists (or the changes are below a certain threshold) for at least N_R successive iterations, the external cycle stops⁵.

At each iteration of the external cycle, the internal cycle is run. For every iteration m of the external cycle, the inputs of the internal cycle are:

- *Initial configuration* $\mathbf{X}^{(best)}$ and its objective function $f^{(best)}$: it refers to the best configuration found so far (the solution provided as output at the iteration $m-1$)
- *Value of the control parameter* C_m
- *Number of solutions to be analysed* N_A
- *Number of solutions to be accepted* N_C

⁵ This kind of stop criterion is typical of many heuristics existing in the literature and avoids fixing a priori the limit number of iterations, but only the number of iterations in which the same solution persists.

PtG and on the size. The values of capacity factors are higher for the rural network than for the semi-urban network: in fact, the minimum capacity factor values for the rural network fall around 50%, whereas for the semi-urban network the minimum capacity factors fall down to 21%. This suggests that the installation of PtG plants at the level of distribution system has to be made by considering the local characteristics of the network.

All the performances of the plants have been obtained by considering the *network effect*, and has been shown with an effective evidence that neglecting its presence can lead to wrong results (e.g., lower capacity factor or slight over-estimation of the reverse power flow).

In conclusion, it can be said that the addition of PtG systems in a distribution network can stabilise the network for very high (even extreme) renewable energy penetrations, thus increasing the ability of a network to host higher penetration of intermittent generation. The deployment of the plants in the real network needs to consider the presence of a proper gas network, which, fed with renewable synthetic gas having the same characteristics of the natural gas, will open new perspectives regarding the decarbonisation the entire energy system.

CRedit authorship contribution statement

Andrea Mazza: Conceptualization, Methodology, Software, Writing - original draft, Writing - review & editing. **Fabio Salomone:** Methodology, Software, Writing - original draft, Writing - review & editing. **Francesco Arrigo:** Software. **Samir Bensaid:** Conceptualization, Funding acquisition. **Ettore Bompard:** Conceptualization, Funding acquisition. **Gianfranco Chicco:** Conceptualization, Writing - review & editing.

Declaration of Competing Interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgment

This contribution has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No. 691797 (project STORE&GO). The paper only reflects the authors' views and the European Union is not liable for any use that may be made of the information contained herein.

The Authors would like to thank Mr. Luca Serra, for the first calculations developed during his MSc degree project.




Fig. 15. The external loop (a) and the internal loop (b) of the SA used for siting and sizing.

The last two inputs are necessary for the stopping criterion of the internal cycle, which is structured as follows: the internal cycle stops when either N_C or N_A are reached. The first condition is usually reached with high C_m (i.e., when many new solutions are accepted), whereas the second condition is usually reached with low C_m (i.e., when the number of accepted solutions decreases, up to the final internal cycles before stopping, in which there is no acceptance of new solutions). In addition, the seed for random number extractions is fixed before starting the iterative process, to enable repeatability of the results obtained.

References

- [1] Mazza A, Cavana M, Mercado Medina EL, Chicco G, Leone P. "Creation of Representative Gas Distribution Networks for Multi-vector Energy System Studies," In: Proc. IEEE International Conference on Environment and Electrical Engineering and 2019 IEEE Industrial and Commercial Power Systems Europe (EEEIC / I&CPS Europe), 11-14 June 2019.
- [2] Yang Z, Gao C, Zhao M. Coordination of integrated natural gas and electrical systems in day-ahead scheduling considering a novel flexible energy-use mechanism. *Energy Convers Manag* 2019;196:117–26.
- [3] Mazza A, Bompard E, Chicco G. Applications of power to gas technologies in emerging electrical systems. *Renew Sustain Energy Rev* 2018;92:794–806.
- [4] Schiebahn S, Grube T, Robinius M, Zhao L, Otto A, Kumar B, Weber M, Stolten D. "Power to Gas," Chapter 39 in *Transition to Renewable Energy Systems*, D. Stolten and V. Scherer (Eds.), Wiley, 2013, pp. 813–848.
- [5] Ghaib K, Ben-Fares F-Z-Z. Power-to-Methane: a state-of-the-art review. *Renew Sustain Energy Rev* Jan. 2018;81:433–46.
- [6] Robinius M, et al. Power-to-Gas: Electrolyzers as an alternative to network expansion – An example from a distribution system operator. *Appl Energy* 2018;210:182–97.
- [7] Salomone F, Giglio E, Ferrero D, Santarelli M, Pirone R, Bensaïd S. Techno-economic modelling of a Power-to-Gas system based on SOEC electrolysis and CO₂ methanation in a RES-based electric grid. *Chem Eng J* 2019;377:120233.
- [8] Estermann T, Newborough M, Sterner M. Power-to-gas systems for absorbing excess solar power in electricity distribution networks. *Int J Hydrogen Energy* 2016;41(32):13950–9.
- [9] Park C, Bigler F, Korba P. Power-to-Gas Concept for Integration of Increased Photovoltaic Generation into the Distribution. *Energy Procedia* 2016;99:411–7.
- [10] Simonis B, Newborough M. Sizing and operating power-to-gas systems to absorb excess renewable electricity. *Int J Hydrogen Energy* 2017;42(34):21635–47.
- [11] El-Taweel NA, Khani H, Farag HEZ. Voltage regulation in active power distribution

- systems integrated with natural gas grids using distributed electric and gas energy resources. *Int J Electr Power Energy Syst* 2019;106:561–71.
- [12] Dalmau AR, Perez DM. Diaz de Cerio Mendaza I, Pillai J.R. “Decentralized voltage control coordination of on-load tap changer transformers, distributed generation units and flexible loads,” *Proc. IEEE Innovative Smart Grid Technologies - Asia (ISGT ASIA)*, 3-6 Nov. 2015.
- [13] de Cerio Mendaza ID, Bak-Jensen B, Chen Z. “Alkaline electrolyzer and V2G system DigSILENT models for demand response analysis in future distribution networks,” *Proc. IEEE Grenoble Conference*, 16-20 June 2013.
- [14] Diaz de Cerio Mendaza I, Bhattarai BP, Kouzelis K, Pillai JR, Bak-Jensen B, Jensen A. “Optimal sizing and placement of power-to-gas systems in future active distribution networks,” *Proc. IEEE Innovative Smart Grid Technologies - Asia (ISGT ASIA)*, 3-6 Nov. 2015.
- [15] Khani H, El-Taweel N, Farag HEZ. Real-time optimal management of reverse power flow in integrated power and gas distribution grids under large renewable power penetration. *IET Gener Transm Distrib* 2018;12(10):2325–31.
- [16] Khani H, El-Taweel N, Farag HEZ. Power congestion management in integrated electricity and gas distribution grids. *IEEE Syst J* 2019;13(2):1883–94.
- [17] Khani H, El-Taweel N, Farag HEZ. Power loss alleviation in integrated power and natural gas distribution grids. *IEEE Trans Ind Informatics* 2019;15(12):6220–30.
- [18] European Project STORE&GO, web: <https://www.storeandgo.info/>.
- [19] Giglio E, Lanzini A, Santarelli M, Leone P. Synthetic natural gas via integrated high-temperature electrolysis and methanation: Part I—Energy performance. *J. Energy Storage* 2015;1:22–37.
- [20] Samavati M, Santarelli M, Martin A, Nemanova V. Thermodynamic and economy analysis of solid oxide electrolyser system for syngas production. *Energy* 2017;122:37–49.
- [21] Bailera M, Lisbona P, Romeo LM, Espatolero S. Power to Gas projects review: Lab, pilot and demo plants for storing renewable energy and CO2. *Renew Sustain Energy Rev* 2017;69:292–312.
- [22] Giglio E, Lanzini A, Santarelli M, Leone P. Synthetic natural gas via integrated high-temperature electrolysis and methanation: Part II—Economic analysis. *J. Energy Storage* 2015;2:64–79.
- [23] Götz M, et al. Renewable Power-to-Gas: A technological and economic review. *Renew. Energy Jan.* 2016;85:1371–90.
- [24] McDonagh S, O’Shea R, Wall DM, Deane JP, Murphy JD. Modelling of a power-to-gas system to predict the levelised cost of energy of an advanced renewable gaseous transport fuel. *Appl Energy* 2018;215:444–56.
- [25] Giglio E, et al. Power-to-Gas through High Temperature Electrolysis and Carbon Dioxide Methanation: Reactor Design and Process Modeling. *Ind Eng Chem Res* 2018;57(11):4007–18.
- [26] Schmidt O, Gambhir A, Staffell I, Hawkes A, Nelson J, Few S. Future cost and performance of water electrolysis: An expert elicitation study. *Int J Hydrogen Energy* 2017;42(52):30470–92.
- [27] Ulleberg Ø, Nakken T, Eté A. The wind/hydrogen demonstration system at Utsira in Norway: Evaluation of system performance using operational data and updated hydrogen energy system modeling tools. *Int J Hydrogen Energy Mar.* 2010;35(5):1841–52.
- [28] E. A. Morosanu, F. Salomone, R. Pirone, and S. Bensaïd, “Insights on a Methanation Catalyst Aging Process: Aging Characterization and Kinetic Study,” *Catalysts*, vol. 10, no. 3, art. 283, Mar. 2020.
- [29] Marocco P, et al. CO2 methanation over Ni/Al hydrotalcite-derived catalyst: Experimental characterization and kinetic study. *Fuel* 2018;225:230–42.
- [30] Morosanu EA, Saldivia A, Antonini M, Bensaïd S. Process Modeling of an Innovative Power to LNG Demonstration Plant. *Energy Fuels* 2018;32(8):8868–79.
- [31] Sinnott RK. *Coulson & Richardson’s Chemical Engineering Design*, 4th ed., vol. 6. Oxford, 2005.
- [32] Seborg DE, Edgar TF, Mellichamp DA. *Process Dynamics and Control*, 2nd editio. John Wiley & Sons, 2003.
- [33] B. A. Ogunnaike and W. H. Ray, *Process Dynamics, Modeling and Control*. Oxford University Press, 1994.
- [34] R. H. Perry, D. W. Green, and J. O. Maloney, *Perry’s Chemical Engineers’ Handbook* 7th edition, 7th ed. The McGraw-Hill Companies, 1999.
- [35] Sundaresan KR, Krishnaswamy PR. Estimation of Time Delay Time Constant Parameters in Time, Frequency, and Laplace Domains. *Can J Chem Eng* 1978;56(2):257–62.
- [36] N. Jenkins, J. B. Ekanayake, and G. Strbac, *Distributed Generation*. London: IER Renewable Energy Series, 2010.
- [37] Enel-Energia, “Enel Energia a tutto storage,” <https://corporate.enel.it/it/media/news/d/2015/12/enel-energia-a-tutto-storage> (in Italian).
- [38] Fink LH, Carlsen K. Operating Under Stress and Strain. *IEEE Spectr* 1978;15(3):48–53.
- [39] A. Mazza, E. Carpaneto, G. Chicco, and A. Ciocia, “Creation of Network Case Studies with High Penetration of Distributed Energy Resources,” *Proc. 53rd International Universities Power Engineering Conference (UPEC 2018)*, 4-7 Sept. 2018.
- [40] E. Carpaneto, G. Chicco, and J. Sumaili Akilimali, “Characterization of the loss allocation techniques for radial systems with distributed generation,” *Electr. Power Syst. Res.*, vol. 78, no. 8, pp. 1396–1406, Aug. 2008.
- [41] A. Mazza and G. Chicco, “Losses Allocated to the Nodes of a Radial Distribution System with Distributed Energy Resources — A Simple and Effective Indicator,” *Proc. International Conference on Smart Energy Systems and Technologies (SEST)*, 9-11 Sept. 2019.
- [42] G. Pretticco, M.G. Flammini, N. Andreadou, S. Vitiello, G. Fulli, and M. Masera, “Distribution System Operators observatory 2018-Overview of the electricity distribution system in Europe”, EUR 29615 EN, Publications Office of the European Union, Luxembourg, 2019.
- [43] Bompard E, Chicco G, Mazza A, Bensaïd S. Deliverable 6.4 Report on the model of the power system with PtG. European Project STORE&GO 2019.
- [44] Bracale A, et al. “Analysis of the Italian distribution system evolution through reference networks”, *Proc. IEEE PES Innovative Smart Grid Technologies Conference. Europe* 2012;14–17:Oct.
- [45] J.M. Bright, Bright Solar Resource Model, web: <https://jamiembright.github.io/BrightSolarModel/>.
- [46] Shirmoharmnadi D, Hong HW, Semlyen A, Luo GX. A compensation-based power flow method for weakly meshed distribution and transmission networks. *IEEE Trans Power Syst* 1988;3(2):753–62.
- [47] P. J. M. van Laarhoven and E. H. L. Aarts, *Simulated Annealing: Theory and Applications*. Dordrecht, Holland: D.Reidel Publ. Company, 1987.